



NOTES:

ALL PIPE AND FITTINGS FROM THE MAIN TO THE GATE VALVE
SHALL BE BRASS WITH I.P. THREADS.

INSTALL VALVE MARKER PER STANDARD DETAIL NO. 10.

2" BLOW-OFF ASSEMBLY

NTS



REVISION DATE
1/8/04

DRAWN
SED

CHECKED
TDK

DISTRICT APPROVED
TDK

PLOTTING SCALE
NTS

FILE NAME
F:\DWGS\DETAILS-2004\HWD-011

DATE APPROVED
3/1/04