



- INSTALL:
- 1 - MAINSIZE X 8" TEE (MJ X FL)
 - 1 - MAINSIZE PLUG (MJ)
 - 1 - 8" GATE VALVE (FL X MJ)
 - 1 - 8" 45° BEND (PE X MJ)
 - 1 - 8" 45° BEND (MJ X FL)
 - 1 - 8" X 2" TAPPED BLIND FLANGE
 - 3 - 8" MEGALUG GLANDS
 - 1 - 2" 45° BRASS STREET ELBOW (IP)
 - 1 - 2 1/2" NST HOSE NOZZLE W/CAP & CHAIN
(DRILL & TAP 1/4" DIA. HOLE IN CAP,
INSERT 1/4" TESTCOCK)
 - 1 - #2 SIZE METER BOX W/TRAFFIC LID
 - 1 - VALVE MARKER PER STANDARD DETAIL NO. 10

8" BLOW-OFF ASSEMBLY

NTS



REVISION DATE 1/30/04	DRAWN SED	CHECKED TDK	DISTRICT APPROVED TDK
PLOTTING SCALE NTS	FILE NAME F:\DWGS\DETAILS-2004\HWD-014		DATE APPROVED 3/1/04