



- 1 - MAINSIZE X 4" TO 10" TEE (RJ X FL)
- 1 - MAINSIZE PLUG (MJ)
- 1 - 4" TO 10" GATE VALVE (FL X RJ)
- 2 - 4" TO 10" D.I. SPOOLS (LENGTHS AS REQ'D)
- 1 - 4" TO 10" 45° BEND (RJ)
- 1 - 4" TO 10" 45° BEND (RJ X FL)
- 1 - 4" TO 10" X 2" TAPPED BLIND FLANGE
- 1 - 2" 45° BRASS STREET ELBOW
- 1 - 2 1/2" NST HOSE NOZZLE W/CAP & CHAIN
- 1 - VALVE MARKER PER DISTRICT DETAIL

NOTES:

- SEE APPROVED MATERIALS LIST.
- ALL PIPE AND FITTINGS SHALL BE FULLY MECHANICALLY RESTRAINED.

4-INCH TO 10-INCH BLOW-OFF ASSEMBLY

NTS



APPROVAL DATE
10/21/2020

DRAWN
SED

CHECKED
DS

Handwritten signature and date: JSD 10/26/20

PLOTTING SCALE
NTS

DETAIL NUMBER
HWD STANDARD DETAIL 13