



NOTES:

- STREET ELLS ARE NOT ALLOWED.
- WATER METER TO BE SUPPLIED BY DISTRICT.
- DIMENSIONS INCLUDE GASKET WIDTHS*.
- SEE APPROVED MATERIALS LIST.
- BED ALL SERVICE MATERIALS IN SAND (MINIMUM 6" AROUND ALL PIPING).
- INSTALL VALVE MARKER PER STANDARD DETAIL.

2-INCH FIRE ASSEMBLY SERVICE

NTS

APPROVAL DATE
10/21/2020

DRAWN
SED

CHECKED
DS

PLOTTING SCALE
NTS

DETAIL NUMBER
HWD STANDARD DETAIL 19

JSD
10/20/20

